



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20115933, Building Permit - Commercial
Address: 1196 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Passed	Thursday, December 01, 2011
In-wall Inspection	John Borns	Passed	Thursday, December 01, 2011

Comments: RELEASE ELECTRICAL SERVICE. OK TO COVER WHEN READY WALL FRAMING AND IN-WALL SYSTEMS.