

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20231975  
Address: 1550 SE HAMBLER RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Shawn Hoffman	Ready for Temp CO	Monday, February 10, 2025

Corrective Action Required:

- |   |      |  |
|---|------|--|
| 1 | Misc | - Provide permanent ladders to roof access in accordance to 306.5 of the international mechanical code |
|   |      | - Complete installation of all stall doors in bathrooms  |
|   |      | - Label Roof Top Units   |
|   |      | - Some GFCI's at RTU's not working   |

Comments: