

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOMCOM20240778
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Plumbing Inspection - Commercial	Shawn Hoffman	Partial	Monday, February 10, 2025

Informational:

1 Misc

PIPING AWAY FROM SLAB OUT 20'

Informational:

2 Misc

Tank in and input side complete, ok to cover.
Inspection of discharge connection pending

Informational:

3

- sanitary down to back of interseptor, ok to cover

Comments: