

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242627
Address: 3509 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Jamie Simerly	Partial	Monday, February 10, 2025

Informational:
1 Misc 2-3-25 Dustin A, Dw is formed and compacted, Approved to pour
02-10-25 Jamie S, DW slope is in compliance with city standards, grout is need on the curb leading in to the approach.

Comments: