

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20242915
Address: 1800 SW HIGHTOWN DR, LEES SUMMIT, MO 64082
Inspected On: Monday, February 10, 2025
Inspected By: Development Center
Expiration Date: 1/20/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Thursday, December 19, 2024

Corrective Action Required:

2	Miscellaneous Correction	provide as graded plot plan -final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation -will check water meter at time of final grade and sod, ensure 14"-18" from top of meter to well lid ring
---	--------------------------	--

Passed for TCO only

Comments: