

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242933
Address: 2218 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Robb Popp	Partial	Tuesday, February 11, 2025

Corrective Action Required:

1	Misc	-Protect storm inlet by proper means (gutter buddy needs needs replaced and separated from inlet with cinder blocks)
---	------	----------------------------------------------------------------------------------------------------------------------

Comments: