

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED**

---

**Permit #:** PRRES20242381  
**Address:** 2213 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Robb Popp	Failed - Stop Work	Tuesday, February 11, 2025

**Corrective Action Required**

1	Miscellaneous Correction	Maintain storm inlet -Remove silt and debris from inlet, replace damaged, worn gutter buddy and install with cinder blocks separating filter from inlet
---	--------------------------	--

**Comments:**