

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20242075
Address: 2229 NW KILLARNEY LN, LEES SUMMIT, MO 64081
Inspected On: Tuesday, February 11, 2025
Inspected By: Development Center
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Ready for Temp CO	Tuesday, February 11, 2025
Corrective Action Required:			
1 Misc	-Complete final grade, sod, splash blocks -Remove sauna tubes from deck piers		

Comments: