

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20244613  
Address: 3445 SE CORBIN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Not Ready	Tuesday, February 11, 2025

Corrective Action Required:

1	Miscellaneous Correction	EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE.
---	--------------------------	--

- Erosion control measures at the front of the lot are either missing and or torn down in areas
- Dirt spoil pile does not have erosion control around it
- NO ADDRESS POSTED

- sidewalk has been installed
- front porch guard rail has been installed

THIS IS NOT A COMPLETE LIST

Not ready for inspection

WALK YOUR PROPERTY BEFORE SCHEDULING YOUR INSPECTIONS

**Comments:**