

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245537
Address: 2759 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, February 11, 2025

Corrective Action Required:

3	Misc	<ul style="list-style-type: none">- Add joist hanger owners entry under minimum bearing- Nail together triple stud pack under double LVLs main floor stairs Address deck- Fire block top of chase next to sliding door- Strap top plate in locations over board in bearing wall great room/ bathroom- Fire block top of chase bedroom 5 /entry- Missing stud bathroom 2
---	------	--

Comments: