



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20115339, Building Permit - Commercial  
Address: 1229 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Failed	Thursday, December 01, 2011

### Corrective Action Required

1	MISC	LIGHTED SIGN NOT UL LABELED. MAY NOT BE FIELD LABELED.
2	MISC	ADDRESS-LABEL ROOFTOP UNIT
3	MISC	ELECTRICAL RECEPTACLE OUTLET FOR SERVICING OF HACR EQUIPMENT NOT FOUND AT ROOFTOP
4	MISC	CLEAR ALL DEBRIS AND UNUSED MATERIAL FROM ROOFTOP
5	MISC	CHECK ALL ELECTRICAL RECEPTACLES: MAKE ALL SOLID TO BOX -- ELIMINATE LOOSENESS AND "SOFTNESS"; ONE AT NORTH WALL HAS APPARENT OPEN NEUTRAL
6	MISC	WATER CLOSET SEAT NOT OPEN FRONT
7	MISC	BOTTOM OF MIRROR GLASS IS > 40" AFF

<b>Occupancy Inspection - Fire</b>	Joe Dir	Passed	Thursday, December 01, 2011
--	---------	--------	-----------------------------

**Comments:**

