

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226232
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Tuesday, February 11, 2025

Corrective Action Required:

1	FIRST FLOOR	*****AREAS APPROVED TO COVER: -Entry canopy ok to cover Addition complete except as noted -Clean room at existing tie in 1E 169. Address penetrations and incomplete rated assembly
---	-------------	--

**Existing side:
Complete except as noted:
-Seal penetrations and gaps at Materials Management and Clean Room

Corrective Action Required:

2	SECOND FLOOR	Above-ceiling OK below: **Addition Complete except at existing south stair: label fire wall **Existing side 2E423, 2E421, 2E422, 2E420, 2E242, 2E241, 2E200J, 2E240, 2E238, 2E239 -Soffits approved
---	--------------	---

Corrective Action Required:

3	THIRD FLOOR	**Addition complete
---	-------------	---------------------

Comments:

