

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20235207  
Address: 2931 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Shawn Hoffman	Failed	Tuesday, February 11, 2025

Informational:

1	Misc	-Nailing of exterior wall sheathing-OK to cover front, north, and south walls
---	------	-------------------------------------------------------------------------------

Corrective Action Required:

2	Misc	Front garage PFH walls only: -Provide 2 anchors per wall sill plate -Nail wall top plate to header w/ 2 rows of 16d @ 3" oc
---	------	-----------------------------------------------------------------------------------------------------------------------------------

Corrective Action Required:

3	MISC	INSPECTED BUILDING 3 - NORTH STAIR TOWER MAIN FLOOR FIRST LAYER ONLY  - SOUTH STAIR TOWER MAIN FLOOR FIRST LAYER ONLY  THREE SHEAR WALLS NORTH, MID-NORTH, AND SOUTH BACK OF BUILDING 3
---	------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: