CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245805

Address: 1109 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Shawn Hoffman Failed Wednesday, February

Residential 12, 2025

Corrective Action Required:

1 Misc PORTAL FRAME INSPECTION

- Missing LUS24 hangers on porch trusses

- CSPF at dinning room approved

- PFH at garage approved

Comments: