

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245422
Address: 3207 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Wednesday, February 12, 2025

Informational:

1	Misc	Garage portal frame nailing inspection only- OK
---	------	---

Corrective Action Required:

2	Misc	-multiple fire blocking issues throughout home. Address before calling for inspection (Penetrations, dead spaces etc.)
---	------	---

Comments: