

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

February 13, 2025

Aesthetic Luxury Spa 10501 E 63RD STREET, UNIT18361 Raytown, MO 64133

Permit No: PRCOM20250181
Project Title: AESTHETIC LUXURY SPA

Project Address: 1237 NE DOUGLAS ST, LEES SUMMIT, MO 64086

Parcel Number: 52910150400000000

Location / Legal MAPLE TREE PLAZA 2ND PLAT---LOT 3 (EX PT IN ROW)

Description:

Type of Work: CHANGE OF TENANT

Occupancy Group: BUSINESS

Description: AESTHETIC LUXURY SPA - CHANGE OF TENANT FOR AESTHETIC CARE - NO CONSTRUCTION

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and /or additional information to the application through the online portal. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200 Fire Department (816) 969-1300

Fire Plan Review Reviewed By: Craig Hill Approved with Conditions

Building Plan Review Reviewed By: Joe Frogge Rejected

2. The project cost, which is used to establish the permit fee, has not been provided.

Action required: Comment is informational. (we need this number for tracking and to calculate permit fee. Even if no construction there is usually painting, signage, furniture, etc. As long as the number is \$12,500.00 or less the minimum \$50 fee will apply)

2/13/2025 - Not addressed.

3. 2018 IPC 403.1 Minimum number of fixtures. Plumbing fixtures shall be provided in the minimum number shown in Table 403.1, based on the actual use of the building or space. Uses not shown in Table 403.1 shall be considered individually by the code official. The number of occupants shall be determined by the International Building Code.

Action required: Drinking fountain and mop sink required. Previous tenant installed mop sink - was it removed? Previous tenant agreed to provide bottled water to clients - a letter from you agreeing to the same will work for the drinking fountain requirement.

2/13/2025 - Not addressed.



DEVELOPMENT SERVICES

The review conducted by	y the City of Lee's Summ	it Development Services De	partment shall not be co	nstrued as

Approved

Reviewed By: Joe Frogge

Licensed Contractors

a structural review of the project.