

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241004
Address: 2532 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Wednesday, February 12, 2025

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">-Driveway and sewer not approved on record-Final grade, sod, downspout and sump pump extension-Seal exterior wall penetrations-Provide sewer tracer wire port at grade-Install two 1/2" lag screws (or approved screws) at each end of deck ledger board-Garage door not self-closing-Provide a continuous and uninterrupted stair handrail to basement-Protect wiring running across bottom of joists in basement per code
---	------	--

Comments: