CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232768

Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Robb Popp Partial Thursday, February 13,

Commercial 2025

Corrective Action Required:

1 STAIR TOWER 1 complete

Corrective Action Required:

2 STAIR TOWER 2 complete

Corrective Action Required:

3 STAIR TOWER 3 complete

Corrective Action Required:

4 FIRST FLOOR Building F

Complete except as noted:

157-NOT READY

389-Walls only ok-complete meps at ceiling and seal dead space

Building G: complete

Building H: complete

Building J:

Seal dead spaces throughout

108-complete dwv

110-complete electrical, seal penetrations at bath, protect nm

Mechanical room walls only

Corrective Action Required:

SECOND FLOOR

Building F:

-Units and corridor complete

Building G:

-Units and corridor complete

Building H:

Units and corridor complete

Building J:

208-Provide truss repair 212-Protecet SER at bedroom

Corrective Action Required:

6 THIRD FLOOR *Building F

-Units and corridor approved

Building G:

-Units and corridor approved

Building H:

-Units and corridor approved

Building J:

-Units and corridor approved

Corrective Action Required: 7

FOURTH FLOOR

*Building F Complete

*Building G: complete

Building H: Complete

Building J: Complete

Corrective Action Required:

ELEVATOR 1

Interior framing ok all floors

Corrective Action Required: **ELEVATOR 2**

Elevator in G: Framing approved

Corrective Action Required:

10 LOWER LEVEL

H, I, J approved

Comments: