## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRSUBD20232726 Address: 2200 NE DOUGLAS ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:	
Water Line - Construction Inspection	Devon Perry	Partial	Friday, February 14, 2025	
Informational:				
1 Misc	7-12-24 DP. Travis' crew was onsite and completed the water crossing under colburn road. They backfilled the trench with AB3 and added steel plates across Colburn R			
	7-15-24 DP. I spoke with Perry Allen and Andy with ESS this morning. ESS is going to remove the AB3 down to 12" above highest point of water casing and will add flow fill to top of existing pavement. They will need to leave steel plates until the flow fill sets up. Onces it is set up, they can remove steel plates and open to traffic. This is being allowed because Clarkson will be redoing Colburn Rd. soon.			
	with a jumper from department. ESS sa being help up. I che called Earl with Inse is currently checking Colburn. We will ei to get figured out or	the live 20" water line. T id the north phase (wher cked with MW and it is n ntric and he knew nothin g on status of CIP's water		

		8-12-24 DP. Dustin worked with ESS and completed the cross tie in of water line A.
Informational: 2 Misc	8-16-24 DP. I met AJ with ESS on site today and we chlorinated all of the public water that have been installed. It will sit over the weekend and flush on monday with samples following.	
	8-19-24 DP. AJ was on site and flushed all public water.	
	2-11-25 DP. Aarons crew with Advanced Excavation is working on the north phase 12"	
	2-14-25 DP. Aarons crew is back onsite working north installing the north phase 12" water line	

## **Comments:**