

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOMCOM20240778
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer Construction Inspection	Devon Perry	Passed	Friday, February 14, 2025

Informational:
1 Misc 2-14-25 DP. Floyds crew connected the sewer pipe from the grease trap to the private sewer main. They tied the wye in to a 6" clay main. They installed tracer wire and also sewer tape.

Comments: