Architect's Supplemental Instructions

HOEFER WELKER

Project: Lee's Summit Police Joint	Contract Information:	ASI Information:
Operations Facility	Contract For: \$	ASI Number: 003
2 NE Tudor Rd,.	Date:	Date: 12/18/2024
Lee's Summit, MO 64086		
Architect Project Number: Owner: City of Lee's Summit 220 SE Green St, Lee's Summit, MO 64063	Architect: Hoefer Welker 4622 Pennsylvania Ave. Suite 1400 Kansas City, Missouri 64112	Contractor: Titan Built 8207 MELROSE DRIVE, SUITE 200 LENEXA, KANSAS 66214

The Contractor shall carry out the Work in accordance with the following supplemental instructions without change in Contract Sum or Contract Time. Proceeding with the Work in accordance with these instructions indicates your acknowledgment that there will be no change in the Contract Sum or Contract Time.

Description: Mechanical changes related to precast concrete coordination and electrical changes due to permit comments.

MECHANICAL

1. Sheet M-101 – Lower Level – HVAC PLAN a. Revised duct routing to avoid beam.

ELECTRICAL

- Sheet E-111 Main Level Lighting Plan

 Revised light fixture to be on emergency lighting inverter for new door.
 Added exit sign over new door.

Attachments: M-101, E-111

ISSUED BY THE ARCHITECT:

Megar Hohm SIGNATURE

Megan Hohensinner PRINTED NAME AND TITLE

<u>12/18/2024</u> DATE