

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241770
Address: 3724 SW KNOXVILLE CT, LEES SUMMIT, MO 640823722 SW KNOXVILLE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Friday, February 14, 2025

Corrective Action Required:

2	Miscellaneous Correction	Both -address pending driveway & sidewalk inspection -will check water meter at time of final grade and sod ensure 14"-18" from top of meter to well lid ring -final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation
---	--------------------------	---

Both passed for TCO only

Builder sent in a TCO extension form and stated that weather conditions were the reason for not completing their correction list. 02/14/25 KBEARD

Comments: