CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243908

Address: 3449 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Shawn Hoffman Failed Friday, February 14,

Residential 2025

Corrective Action Required:

2 Misc - Missing switch plate at stairs kitchen

- Sump discharge is to be 36" away from foundation - Final grading

- Final grading and sod

- Provide gutters and downspouts with splash pads

- Uncover water meter for inspection

- Pay all fees

Comments: