

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245422  
Address: 3207 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Tuesday, February 18, 2025

Informational:

1 Misc

Garage portal frame nailing inspection only- OK

Corrective Action Required:

2 Misc

- nail plate under header at garage portal into header
- seal top plate penetration at primary bath
- seal dead space at stairwell
- provide strapping to plans at primary bedroom windows
- plans call for continuous header at rear great room windows and side dining room window
- missing lateral bracing on multiple trusses throughout (checked A4 was not done check throughout)

**Comments:**