

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243543
Address: 3208 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Tuesday, February 18, 2025

Corrective Action Required:

2 Misc

- pay all fees
- address pending driveway inspection
- provide as graded plot plan
- final grade and sod
- splash blocks and sump pump discharge to extend 36" from foundation
- install gutters
- uncover covered water meter
- identify and land sewer tracer wire
- seal all exterior penetrations
- deck post to beam connections not to code

Comments: