

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242945

Address: 3718 SW KNOXVILLE CT, LEES SUMMIT, MO 640823716 SW KNOXVILLE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Tuesday, February 18, 2025

Corrective Action Required:

2	Miscellaneous Correction	3716 Passed for TCO only
---	--------------------------	-----------------------------

		3718 Passed for TCO only
--	--	-----------------------------

Both units
sod and splash pads are not installed
Land sewer tracer wire in boxes
Side walks are not installed
Driveway finals are not completed
Plot has not had final grading
Sump pump extensions must extend out 3 feet from the foundation

Comments: