

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235207
Address: 2931 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Partial	Tuesday, February 18, 2025

Informational:

1	LOWER LEVEL	-Both stair A enclosures: stair side 2nd layer
---	-------------	--

Informational:

2	FIRST FLOOR	-Both stair A enclosures: stair side 1st layer ok
---	-------------	---

Corrective Action Required:

3	Misc	1st floor north&south stair A: 2nd layer installed; however, provide lapping at edge
---	------	--

Comments: