## CITY OF LEE'S SUMMIT **Development Services Department** 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20245537

2759 SW 11TH TER, LEES SUMMIT, MO 64081 Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date: All Rough Inspection -Shawn Hoffman Failed Wednesday, February

Residential 19, 2025

Corrective Action Required:

- Strap top plate in locations over board in bearing wall great room/ 1 Misc

bathroom

2/19/25 not done

4 locations on this wall, all DWV, ductwork. Boca plate are not a strap minimum of 6" past over bored area each side with minimum of 4 10D nails

each side.

**OK TO INSULATE** 

Comments: