

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20250181
Address: 1237 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Shawn Hoffman	Failed	Thursday, February 20, 2025

Corrective Action Required:

2	Misc	<ul style="list-style-type: none">- protect plumbing at ADA compliant sink in bathroom- All outlets and switches need covers- Address open electrical throughout- Install missing light fixtures
---	------	---

Comments: