

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245422  
Address: 3207 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, February 20, 2025

Informational:

1	Misc	Garage portal frame nailing inspection only- OK
---	------	---

Corrective Action Required:

2	Misc	-provide strapping to plans at primary bedroom windows( lsta18 from stud to rim)
---	------	--

**Comments:**