



**LEE'S SUMMIT**  
MISSOURI



---

**FIRE DEPARTMENT**

**Prevention Division**  
**(816)969-1300**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20246426	Date:	February 21, 2025
Project Title:	K + R WHOLESale	Applicant:	
Location:			
1460 SE BROADWAY DR, LEES SUMMIT, MO 64081		ALLIANCE FIRE PROTECTION LLC	
Type of Work:		130 W 9TH AVE STE 101	
Occupancy Group:	S-1	KANSAS CITY, MO 64116	
Description:	K + R WHOLESale - NEW	Primary: (913) 888-0647	
WAREHOUSE WITH OFFICE			
Construction Type:	Type VB (Unprotected)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review**

**Reviewed By: Craig Hill**

**Released for Construction**

1. 2018 IFC 903.4.2- Alarms. Approved audible and visual devices shall be connected to every automatic sprinkler system. Such sprinkler water-flow alarm devices shall be activated by water flow equivalent to the flow of a single sprinkler of the smallest orifice size installed in the system. Listed alarm notification devices shall be provided on the exterior and interior of the building in an approved location. Where a fire alarm system is installed, actuation of the automatic sprinkler system shall actuate the building fire alarm system.

Information only.

2. 2018 IFC 904.4.2- Alarm testing. Notification appliances, connections to fire alarm systems, and connections to approved supervising stations shall be tested in accordance with this section and Section 907 to verify proper operation.

Information Only: Call 816-969-1300 to schedule alarm testing, 24 hours in advance. Coordinate with sprinkler testing.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**