

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231105

Address: 800 NW WARD RD, Unit:IR, LEES SUMMIT, MO 64086800 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Friday, February 21, 2025

Corrective Action Required:

1 Misc

Pre final for units only
Building D:

****4th floor

-Clarify rating for glazing in office window

-Install threshold at stairway door

-Mechanical/storage room not ready

1438-Receptacle at bathroom is not GFCI protected

1443-Uncover sprinkler heads, island receptacle not working

144-exterior incomplete

Comments: