



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114738, Building Permit - Commercial
Address: 1702 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Monday, December 05, 2011

Partial Correction
1 MISC

OK TO POUR WHEN READY FOOTING/PAD TO SUPPORT
GROUND-MOUNTED HVAC EQUIPMENT OUTSIDE NW CORNER
OF BLDG; NOTED THAT A/E DIRECTIONS FOR REINFORCEMENT
ARE VAGUE.

Comments: