

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245503  
Address: 2619 SW BARLEY FIELD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Dustin Agcopra	Failed	Monday, February 24, 2025

Corrective Action Required:

1	Misc	2-24-25 Dustin A, DW has been formed and compacted. Their is standing water in approach and will need to be removed, recompact and called back in for another pre pour inspection. Fail
---	------	---

**Comments:**