

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245503
Address: 2619 SW BARLEY FIELD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Failed	Monday, February 24, 2025

Corrective Action Required:

1	Misc	2-24-25 Dustin A, DW has been formed and compacted. Their is standing water in approach and will need to be removed, recompact and called back in for another pre pour inspection. Fail
---	------	---

Comments: