

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245503  
Address: 2619 SW BARLEY FIELD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Dustin Agcopra	Failed	Monday, February 24, 2025

Corrective Action Required:

1	Misc	2-24-25 Dustin A, Sw is formed and slopes are in compliance. There is standing water, spots where aggregate is not deep enough as well as spots that are not compacted enough. Will need fixed and another pre pour called in. Fail.
---	------	--

**Comments:**