

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245503  
Address: 2619 SW BARLEY FIELD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Dustin Agcopra	Failed	Monday, February 24, 2025

Informational:

1	Miscellaneous Correction	Erosion control is in place and must be properly maintained until CofO
---	-----------------------------	--

Corrective Action Required:

2	DCM3 ESC REQUIRED 2 DAY	2-24-25 Dustin A, Silt fence is down, Street needs cleaned of mud and gravel. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	----------------------------	--

**Comments:**