

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241004  
Address: 2532 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Ready for Temp CO	Friday, February 14, 2025

Corrective Action Required:

1	Misc	-Driveway and sewer not approved on record -Final grade, sod, downspout and sump pump extension -Provide sewer tracer wire port at grade -Install two 1/2" lag screws (or approved screws) at each end of deck ledger board
---	------	--

Comments: