

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245981

Address: 2532 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Khanh Nguyen	Partial	Tuesday, February 25, 2025

Informational:

1 Misc

Pool bonded:

-perimeter, handrail, bonding jumper to equipment location

**Pool water bonding not installed

**Expose underground gas line. Provide pressure test

Comments: