CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242328 Address: 3505 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Tuesday, February 25, 2025

Corrective Action Required:

2	Miscellaneous			
	Correction	 Address excessive slop of front porch 		
		- Provide guard at front porch porch		
		- Open electrical outside garage		
		- Lock out in panel for water heater		
- Dead outlet basement bath - GFCI protection required in - Secure electrical whip of wa - Secondary lock at front doo		- Complete hardware at owner entrance door		
		- Dead outlet basement bathroom		
		- GFCI protection required in mechanical room		
		- Secure electrical whip of water heater by conduit		
		- Secondary lock at front door		
		 Complete deck , deck stairs, landing 		
		- Seal exterior penetrations		
		 Sump discharge to be 36" away from foundation 		
		- Provide gutters with downspouts, splash pads to divert water at least 36'		
	away from foundation			
		- Final grading and sod		
		- Uncover water meter for inspection		
		- Driveway inspection pending		
		- Sidewalk inspection pending		
		 Revision of plot plan to address the location of deck 		

No improvements since last inspection. Please walk your property before scheduling inspections

Not ready. KBEARD 02/24/25 9am

Comments: