

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20235733  
Address: 209 SE GREEN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Robb Popp	Partial	Tuesday, February 25, 2025

Informational:

1	Misc	<ul style="list-style-type: none"><li>-Conduit from mech room 118 to west exterior</li><li>-Communication conduit from 118 to line 5 (108 mechanical)</li><li>-Conduit for (4) receptacles at SW corner of City Hall</li><li>-Conduit from SE sidewalk to NE corner and East to courtyard stairs and clocktower</li><li>-Christmas tree run at SE corner of city hall to quayside box roughly 15' from west side of building</li><li>-Ground ring with (3) ground rods at transformer location for service disconnect</li><li>- West side wicket inspection passed and is okay to cover</li><li>-East side wickets and ballard lighting</li><li>-East wicket, Ballard and holiday lighting</li><li>- Electrical street lighting conduit west side of Johnson street south of Cooper</li><li>-East side of Green street tree planters</li><li>-Corner of Green and 3rd conduit for (7) light poles and (5) tree receptacles</li><li>-South side of 3rd street (3) tree boxes and (3) light poles</li><li>-North side of 3rd street complete from Green to Johnson St</li></ul>
---	------	---

Comments:

