

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245539
Address: 1625 SW ARBORWAY TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, February 26, 2025

Corrective Action Required:

1	Miscellaneous Correction	-address studs in master bath exterior wall board for dwv. (R602.6(1))
---	--------------------------	--

Corrective Action Required:

2	Misc	Inspection denied no address posted.
---	------	--------------------------------------

Comments: