

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20240118  
Address: 515 NW MOORE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Robb Popp	Partial	Wednesday, February 26, 2025

Corrective Action Required:		
1 Misc	-Complete fur downs around plumbing etc, seal penetrations at corridors	
Corrective Action Required:		
2 ELEVATOR 1	-Shaft layer approved	
	-1st and 2nd layer approved	
Corrective Action Required:		
3 ELEVATOR 2	-Ceiling assembly complete	
Corrective Action Required:		
4 STAIR TOWER 1		
Corrective Action Required:		
5 STAIR TOWER 2	RC at ceilings ok	
Corrective Action Required:		
6 STAIR TOWER 3		
Corrective Action Required:		
7 FIRST FLOOR	-RC at ceiling joists and 16" below ceiling at corridor walls from 135-108	
	-Screw pattern at corridor ceiling ok	
	-RC at units and corridor approved except as noted:	
	117-NOT READY	
Informational:		
8 SECOND FLOOR	-RC at ceiling joists and 16" below ceiling at corridor walls from 235-208	
	-Screw pattern at corridor ceiling ok	

-Screw pattern at corridor ceiling ok  
-RC at units and corridor approved except as noted:  
-Screw pattern at units and corridor to firewall except as noted:  
217-1st layer at non shaft assembly walls both sides, both shafts

Informational:

9 THIRD FLOOR

-RC at ceiling joists and 16" below ceiling at corridor walls from 335-308  
-Screw pattern at corridor ceiling ok  
-Pre rock behind showers at 335-332  
-RC at units and corridor to firewall  
\*\*Screw pattern at units and corridor to firewall except as noted:  
317-1st layer at non shaft assembly walls both sides, both shafts

Informational:

10 FOURTH FLOOR

-RC at ceiling joists and 16" below ceiling at corridor walls from 435-408  
-Screw pattern at corridor ceiling ok  
-Pre rock behind showers at 435-416  
-North mechanical shaft- 1st, 2nd, 3rd, 4th layer and hat channel at ceiling-SEAL GAPS AND PENETRATIONS  
\*\*RC at units and corridor to Fire wall only ok to cover  
\*\*Screw pattern at units and corridor to firewall except as noted:  
417-1st layer at non shaft assembly walls both sides, both shafts  
  
\*\*Update plans for new UL assembly on corridor and dividing walls

**Comments:**