

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20243620
Address: 3216 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082
Inspected On: Wednesday, February 26, 2025
Inspected By: Development Center
Expiration Date: 3/24/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Wednesday, February 26, 2025

Corrective Action Required:

1	Misc	-As graded plot plan required -Final grade, sod, splash blocks etc -Sidewalk inspection pending -Secure AC whip
---	------	--

Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Thursday, January 23, 2025
---	------------------	-------------------	----------------------------

Corrective Action Required:

1	Misc	-As graded plot plan required -Final grade, sod, splash blocks etc -Sidewalk inspection pending -Secure AC whip
---	------	--

Comments: