

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242079
Address: 1604 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Dustin Agcopra	Failed	Wednesday, February 26, 2025

Corrective Action Required:

1	Misc	Erosion control in compliance at time of inspection
---	------	-----------------------------------------------------

Corrective Action Required:

2	DCM3 ESC REQUIRED 2 DAY	1/22/25 Dustin A, Dirt from a skid steer id on sidewalk and along curb . No erosion control in that spot. Road and curb along with sidewalk needs to be cleaned. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	----------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Corrective Action Required:

3	DCM3 ESC REQUIRED 2 DAY	2-26-25 Dustin A, Waddles installed but sidewalk still needs cleaned as well as curb line. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	----------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: