

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20245503
Address: 2619 SW BARLEY FIELD DR, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Dustin Agcopra	Failed - Stop Work	Wednesday, February 26, 2025

Informational

1	Miscellaneous Correction	Erosion control is in place and must be properly maintained until CofO
---	--------------------------	--

Corrective Action Required

2	DCM3 ESC REQUIRED 2 DAY	2-24-25 Dustin A, Silt fence is down, Street needs cleaned of mud and gravel. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 2-26-25 Dustin A, Silt fence still down. Remove restroom from stormbox
---	-------------------------	--

Comments: