

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242212  
Address: 373 NW PATCH CT, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Kyle Beard	Failed	Wednesday, February 26, 2025

Corrective Action Required:

2	Miscellaneous Correction	-Small garage overhead door header does not extend all the way to to king stud on the south side -Nail plate is needed in master bathroom to laundry room at hot water pipe -HVAC duct support bracket in basement family room is broken -Joist bracket for I joist in closet 4 is missing -BOCA plate is required for protection in top plate of bedroom 4 to bar area at water and DWV lines -No gas pressure gauge on system at the time of inspection
---	--------------------------	--

Comments: