

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244953  
Address: 1909 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Ready for Temp CO	Thursday, February 27, 2025

Corrective Action Required:

1	Misc	-sod -splash blocks and sump pump discharge to extend 36" from foundation -address pending driveway inspection -will check final grade at later date (to much snow in ground) -back porch stairs has risers greater than 7 3/4 of an inch in height -backyard security lights are covered with plastic sheeting -seal gas line at exterior siding
---	------	---

Passed for TCO only

Comments: