

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240001  
Address: 2604 NE WOODLAND OAK DR, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Ready for Temp CO	Thursday, February 27, 2025

Corrective Action Required:

1	Misc	-Provide sewer tracer wire port at grade -Sod and downspout splashblocks
---	------	---

**Comments:**