

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240001  
Address: 2604 NE WOODLAND OAK DR, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Tuesday, February 11, 2025

Corrective Action Required:

1 Misc

- Provide sewer tracer wire port at grade
- Provide guardrail at open side of front stoop more than 30" above final grade, as measure from 36" out from edge down to grade
- Glazing in the pantry door shall be safety tempered glazing

**Comments:**